


TOP VIEW




FRONT VIEW

NOTES:

1. USE ONE "SPACER STATION" FOR EVERY 5 FEET OF DUCT BANK.
2. EACH SPACER STATION CONSISTS OF:
 - 2 EACH CAT. No. 8W34-2
3. PLACE ORDERS FOR SPACERS BY INDIVIDUAL CATALOG NUMBERS.
4. THE DUCT BANK MUST BE HELD DOWN DURING AND IMMEDIATELY AFTER THE CONCRETE POUR. THIS IS NECESSARY DUE TO THE FLOATATION CAUSED BY DUCT BANK BUOYANCY AND CONCRETE CHURNING.

NOTES: (CONTINUED)

5. HOLD DOWN BARS ARE NOT SHOWN ON THIS DRAWING.
6. CONDUIT, PLASTIC CABLE TIES AND ANY REBAR THAT MAY BE REQUIRED IS TO BE SUPPLIED BY OTHERS.
7. "(TYP)" INDICATES THE DIMENSION IS TYPICAL OF TWO OR MORE PLACES.
8. THE CONDUIT SPECIFICATIONS SHOWN ON THIS DRAWING ARE FOR VISUAL PRESENTATION ONLY.



RIGHT
SIDE
VIEW


CONDUIT DIMENSIONS

IPS SCHEDULE 40

NOMINAL SIZE	ACTUAL OD
2"	2.375
8"	8.625

**UNDERGROUND DEVICES
CATALOG NUMBERS:
2 EA. 8W34-2**

SCALE:




**8W34-2 WUNPEECE® DUCT
SPACER** Spacer Station to Accomodate 4 Ea. 8"
Conduits With 12.000" Center to Center
Separation & 2 Ea. 2" Sch. 40 PVC Conduits

SCALE: See At Left DESIGNED BY: Don McCoy DETAIL BY: SWendland CHECKED BY: Don McCoy


DATE: 5-21-19 APPROVED BY: REVISION:

**1st Designed For UDI LIBRARY OF
OUTLINE & INSTALLATION DRAWINGS FOR AUTOCAD®**

UNDERGROUND DEVICES, INC. DRAWING NUMBER: **90-11052**
NORTHBROOK, ILLINOIS 60062 - PHONE: (847) 205-9000 PAGE 1 OF 3





8W34-2
SPACER



8W34-2
SPACER



ORTHOGRAPHIC VIEWS OF WUNPEECE SPACERS



PERSPECTIVE VIEWS OF
WUNPEECE SPACERS

8W34-2 WUNPEECE® DUCT
SPACER Spacer Station to Accomodate 4 Ea. 8"
Conduits With 12.000" Center to Center
Separation & 2 Ea. 2" Sch. 40 PVC Conduits


SCALE: See At Left	DESIGNED BY: Don McCoy	DETAILED BY: SWendland	CHECKED BY: Don McCoy
DATE: 5-21-19	APPROVED BY:	REVISION:	


1st Designed For UDI LIBRARY OF
OUTLINE & INSTALLATION DRAWINGS FOR AUTOCAD®

UNDERGROUND DEVICES, INC.	DRAWING NUMBER: 90-11052
NORTHBROOK, ILLINOIS 60062 - PHONE: (847) 205-9000	PAGE 2 OF 3

THIS DRAWING AND PROPRIETARY DESIGN IS SOLELY THE PROPERTY OF UNDERGROUND DEVICES, INC. AND IS SUBMITTED WITH THE UNDERSTANDING THAT IT WILL BE KEPT IN STRICT CONFIDENCE.

THIS INFORMATION IS BASED ON OUR EXPERIENCE TO DATE AND WE BELIEVE IT TO BE RELIABLE. IT IS INTENDED ONLY AS A GUIDE FOR USE AT YOUR DISCRETION AND RISK. WE CANNOT GUARANTEE FAVORABLE RESULTS AND ASSUME NO LIABILITY IN CONNECTION WITH ITS USE OR USE OF THE PRODUCTS DESCRIBED.





PERSPECTIVE VIEW OF
DUCT BANK

**8W34-2 WUNPEECE® DUCT
SPACER** Spacer Station to Accomodate 4 Ea. 8"
Conduits With 12.000" Center to Center
Separation & 2 Ea. 2" Sch. 40 PVC Conduits

SCALE: See At Left	DESIGNED BY: Don McCoy	DETAILED BY: SWendland	CHECKED BY: Don McCoy
DATE: 5-21-19	APPROVED BY:	REVISION:	

1st Designed For UDI LIBRARY OF
OUTLINE & INSTALLATION DRAWINGS FOR AUTOCAD®

UNDERGROUND DEVICES, INC. NORTHBROOK, ILLINOIS 60062 - PHONE: (847) 205-9000	DRAWING NUMBER: 90-11052 PAGE 3 OF 3
--	---



THIS DRAWING AND PROPRIETARY DESIGN IS SOLELY THE
PROPERTY OF UNDERGROUND DEVICES, INC. AND IS SUBMITTED
WITH THE UNDERSTANDING THAT IT WILL BE KEPT IN STRICT
CONFIDENCE.

THIS INFORMATION IS BASED ON OUR EXPERIENCE TO DATE AND WE
BELIEVE IT TO BE RELIABLE. IT IS INTENDED ONLY AS A GUIDE FOR
USE AT YOUR DISCRETION AND RISK. WE CANNOT GUARANTEE FAVORABLE
RESULTS AND ASSUME NO LIABILITY IN CONNECTION WITH ITS USE OR
USE OF THE PRODUCTS DESCRIBED.